



**ABOVE GROUND BULK STORAGE TANKS
& FUEL DISPENSING SITES**
OFFICE OF ATTORNEY GENERAL
FIRE MARSHAL
SFN 60309 (12-2016)

State Fire Marshal
250 N 31st Street Suite 7
Bismarck ND 58501-5557
Phone: 701-328-5555
Fax: 701-328-5557

Owner Name		Company Name	
Street Address			
City		State	ZIP Code
Mailing Address			
City		County	State ZIP Code
Office Telephone Number	Cell Telephone Number	Email Address	
Contact Person			
Signature			Date

North Dakota Century Code §18-01-16 states if the State Fire Marshal or a Deputy State Fire Marshal finds any building or upon any premises any conditions which is a danger or a menace to the safety of life and limb of the occupants of that building or of any adjacent building, such officer shall issue an order for immediate removal or correction of the dangerous condition. Any owner, lessee, agent, or occupant upon whom an order of abatement issued under this section is served, who fails to comply with the order within the time specified therein, is guilty of a Class B misdemeanor, and is guilty of a Class A misdemeanor upon a second or subsequent offense.

Re-Inspection Date

All Tanks

*NFPA	Explanation	Yes	No
22.5.2.4	Tank supports protected	<input type="checkbox"/>	<input type="checkbox"/>
21.4	Tank(s) built for aboveground use	<input type="checkbox"/>	<input type="checkbox"/>

*National Fire Protection Association

1993 To Present Fuel Dispensing (Tanks) Only

NFPA	Explanation	Yes	No
4.3.2.3	Individual tank capacity less than or equal to 12,000 gallons, new tanks only	<input type="checkbox"/>	<input type="checkbox"/>
4.3.2.3	Aggregate tank capacity less than or equal to 48,000 gallons, new tanks only	<input type="checkbox"/>	<input type="checkbox"/>
4.3.3.3	If tank(s) are vaulted, meets NFPA 30A	<input type="checkbox"/>	<input type="checkbox"/>
4.3.4	If tank(s) are fire resistant, meets NFPA 30A (fire resistant tank)	<input type="checkbox"/>	<input type="checkbox"/>
22.4.2.4	Vent piping for tanks 12 feet above grade	<input type="checkbox"/>	<input type="checkbox"/>

Pre-1993 Fuel Dispensing (Tank Locations From)

NFPA	Explanation	Separation	Yes	No
4.3.2.4	Building(s)	5'	<input type="checkbox"/>	<input type="checkbox"/>
4.3.2.4	Public way	5'	<input type="checkbox"/>	<input type="checkbox"/>
4.3.3.4	Adjoining property line	Insert Separation 15'	<input type="checkbox"/>	<input type="checkbox"/>
4.3.2.4	Adjacent tank	3'	<input type="checkbox"/>	<input type="checkbox"/>
22.4.2.4	Nearest LP-Gas cylinder	20'	<input type="checkbox"/>	<input type="checkbox"/>

1993 To Present Fuel Dispensing (Tank Locations From)

NFPA	Explanation	Vaulted or Fire Resistive	Non-Vaulted or Non-Fire Resistance	Yes	No
4.3.2.4	Building(s)	25'	50'	<input type="checkbox"/>	<input type="checkbox"/>
4.3.2.4	Fuel dispenser(s)	25'	50'	<input type="checkbox"/>	<input type="checkbox"/>
4.3.3.4	Public way	25'	50'	<input type="checkbox"/>	<input type="checkbox"/>
4.3.2.4	Adjoining property line	25'	50'	<input type="checkbox"/>	<input type="checkbox"/>
4.3.2.4	Adjacent tanks	3'	3'	<input type="checkbox"/>	<input type="checkbox"/>
22.4.2.4	Nearest LP-Gas cylinder	20'	20'	<input type="checkbox"/>	<input type="checkbox"/>

Bulk Operations

NFPA	Explanation	Separation	Yes	No
22.4.1	Building(s)	5'	<input type="checkbox"/>	<input type="checkbox"/>
22.4.1	Public way	5'	<input type="checkbox"/>	<input type="checkbox"/>
28.4	Loading dock	25'	<input type="checkbox"/>	<input type="checkbox"/>
22.4.1	Adjoining property line	5' - 20'	<input type="checkbox"/>	<input type="checkbox"/>
22.4.2	Adjacent tanks	3"	<input type="checkbox"/>	<input type="checkbox"/>
22.4.2.4	Nearest LP-Gas tank	20'	<input type="checkbox"/>	<input type="checkbox"/>

All Tanks (Fuel Operations)

NFPA Pre-1993	NFPA 1993 Present	NFPA Bulk	Explanation	Yes	No
4.3.7.2	4.3.7.2	22.5.1.3	Tank(s) protected from physical damage	<input type="checkbox"/>	<input type="checkbox"/>
22.7	22.7	22.7	Emergency vent provided	<input type="checkbox"/>	<input type="checkbox"/>
27.6.1	27.6.1	27.6.1	Piping protected from physical damage and supported	<input type="checkbox"/>	<input type="checkbox"/>
22.11/ 22.12.5	22.11/22.12.5	22.11/22.12.5	Spill control provided and kept clear of combustibles	<input type="checkbox"/>	<input type="checkbox"/>
NA	NA	100.2.2	40 B:C Fire extinguisher provided and maintained	<input type="checkbox"/>	<input type="checkbox"/>
4.2.4	4.2.4	NA	Tank provided with solenoid-type valve	<input type="checkbox"/>	<input type="checkbox"/>
63.9.1	63.9.1	NA	Fire valve installed and maintained	<input type="checkbox"/>	<input type="checkbox"/>
NA	4.3.6.3	NA	Overfill protection has means to sound audible alarm at 90% capacity	<input type="checkbox"/>	<input type="checkbox"/>
NA	NA	6.5.4.2	Bonding cables provided	<input type="checkbox"/>	<input type="checkbox"/>
NA	NA	22.13	Internal and external valves installed and maintained	<input type="checkbox"/>	<input type="checkbox"/>
4.3.7.1	4.3.7.1	NA	Tank not enclosed by vault shall be enclosed by chain link fence 6 ft high with gate and separated from fence by 10ft	<input type="checkbox"/>	<input type="checkbox"/>

Dispensing Area

NFPA Pre-1993	NFPA 1993 Present	Explanation	Yes	No
6.7	6.7	Emergency shutoff provided	<input type="checkbox"/>	<input type="checkbox"/>
9.10.2.2	9.10.2.2	40 B:C Fire extinguisher provided and maintained	<input type="checkbox"/>	<input type="checkbox"/>
9.2.5.4	9.2.5.4	Proper emergency and warning signs provided	<input type="checkbox"/>	<input type="checkbox"/>
NA	9.5	Signs "Unattended Self Service"	<input type="checkbox"/>	<input type="checkbox"/>

Remarks

If the owner, lessee, agent or occupant of any building described in an abatement order is aggrieved by such order and desires a hearing thereon, the person may complain or appeal in writing to the State Fire marshal within five days from the service of the order, and the State Fire marshal shall investigate said complaint. Unless the order is revoked, modified, or vacated, it must remain in force and be complied with by such owner, lessee, agent, or occupant within the time fixed in said order, North Dakota Century Code § 18-01-17.